



DEPARTMENT OF TRANSPORTATION
Fresno Area Express ♦ Fleet ♦ Handy Ride

ADDENDUM NO. 7
FACILITY UPGRADE PROJECT
Bid File 3839

NOTICE TO ALL BIDDERS

This Addendum is attached to and made a part of the above entitled specifications for the City of Fresno with a scheduled bid opening of **3:00 P.M. February 8, 2022**

All changes and or clarifications will appear in **bold underlined type**.

The attached documents have been made part of the specification:

1. **The bid specifications have been updated. The original specifications have been recalled, and are replaced with new file called "UPDATED SPECIFICATIONS". Please refer to the Planet Bids "Documents" tab to view and/or download the new specification.**
Changes to City of Fresno Project Labor Agreement (PLA)/Community Workforce Agreement and Updated Compliance Forms are now included.
Changes appear in red underline.
2. **Street Improvement Plan (Separate Attachment)**
3. **Refer to attached RFI Questions and Answers (Included with this Addendum)**

City of Fresno
➤ END OF ADDENDUM NO. 7

BRIAN CETTI
Capital Development Specialist

The bidder shall sign below indicating he/she has thoroughly read and understands the contents of this Addendum.

Signed: _____

Company: _____

This addendum is being distributed ONLINE only and will not be sent by U.S. Mail. The bidder shall submit a signed copy of this addendum with their bid.

Addenda to date: 7



Pre-Bid REQUEST FOR INFORMATION

RFI No: 3
Date: 01/25/22

Submitted to: City of Fresno	Submitted By: David Silva
Attention: Sandra Gamez	E-mail: estimating@amgassociatesinc.com
Phone: 661-251-7401	Fax: 661-251-7401

Project:	Fresno Area Express Facility Improvement	Spec. Section:	
Location:		Drawing #:	A-500, A-610, A-611
Sent Via	Email	Detail:	

The following information is requested:

- 1) Spec section 08-51-13-1 aluminum windows call outs out more of a thermally broken fixed "window" from a storefront manufacturer, doesn't call out a specific model of window. We were going to go in with 8400TL Kawneer window if this is acceptable. The details on plan A-611 show more of a thermally broken storefront system which would be more like a 451T from Kawneer. On detail #11 it states, "inside set thermally broken aluminum window frame" and shows a storefront. Please clarify what direction you would like us to go an aluminum window or aluminum storefront.
- 2) On detail #1 and #2 on plan A-500 states a glass block, but there is no reference to this in the specs, window schedule or on the floor plans, we want to make sure we are not missing anything or if this scope will be handled by others. Please provide more details on this window/ locations or model/ type.
- 3) Please provide factory finish "color" for aluminum system on Plan A-610 window schedule, window "W1" states PT-2 painted finish which references dark bronze, this is offered in a anodized finish in lieu of paint and is cheaper than a painted finish. Please clarify finishes on all windows and if the dark bronze anodized is acceptable on "W1"?

Response:

- 1. Aluminum windows are to be used; verify that windows meet the standards in the Specifications.
 - 2. Glass unit masonry is called out on the building elevations (A-241 and A-242). Refer to Spec Section 04 23 00 Glass Unit Masonry within the Technical Specifications.
 - 3. Design intent for window W-1 is to match finish of adjacent door frame. W1 to be painted as specified in Drawings.
- Jiah Hong, Stantec 1/25/2022



Pre-Bid REQUEST FOR INFORMATION

RFI No:	4
Date:	01/25/22

Submitted to: City of Fresno	Submitted By: David Silva
Attention: Sandra Gamez	E-mail: estimating@amgassociatesinc.com
Phone: 661-251-7401	Fax: 661-251-7401

Project:	Fresno Area Express Facility Improvement	Spec. Section:	
Location:		Drawing #:	C101
Sent Via	Email	Detail:	

The following information is requested:

Ref. plan sheet C101 – Entry Gate Enlargement Plan A/C101: Please clarify if the work indicated at the parking lot access area per the Entry Gate Enlargement plan A/C101 is part of this bid solicitation (Part of the Contract work). Since this area has a large “X” of this area of work, and the note indicates the work is “per Offsite Street Improvement Plans...” it would appear this entire Entry Gate area is part of another Off-Site package and therefore NOT a part of this bid solicitation. Please confirm if this work is “part of the contract” or if this work is N.I.C. and thus by others. If this work is N.I.C. (by others) please indicate the limits of the Off-Site work by others (where the work of this contract begins). NOTE: We did not find any “Off-Site” drawings 15-C-18729 or 15-C-18731 issued as part of this solicitation.

Response:

The improvements depicted in Detail A/C101 are to be included in the scope of the work for the project and shall be constructed per the approved off-site street plans, drawing 15-C-18729 thru 15-C-18731, included with this addendum.

Michael Osborn, Provost & Pritchard 1/26/2022



Pre-Bid REQUEST FOR INFORMATION

RFI No: 5
Date: 01/25/22

Submitted to: City of Fresno	Submitted By: David Silva
Attention: Sandra Gamez	E-mail: estimating@amgassociatesinc.com
Phone: 661-251-7401	Fax: 661-251-7401

Project:	Fresno Area Express Facility Improvement	Spec. Section:	051200
Location:		Drawing #:	
Sent Via	Email	Detail:	

The following information is requested:

Spec Section 051200-3 1.7 A & B Quality Assurance states:

A. Fabricator Qualifications: a qualified fabricator that participates in the AISC Quality certification program and is designated an AISC-Certified plant, category BU or is accredited by the IAS Fabricator inspection program for structural steel.

Please confirm if it is acceptable that the AISC Certification for the structural steel fabricator may be waived so long as all structural steel fabrications are performed according to all AISC Specifications and tolerances.

B. Installer Qualifications: A qualified installer who participates in the AISC quality certification program and is designated and AISC Certified Erector, Category ACSE.

Please confirm that it is acceptable that the AISC Certification for the structural steel erector may be waived so long as all structural steel erecting and installation will be done according to all AISC Specifications and tolerances.

Response:

A. It is not acceptable to waive AISC Certification.

B. It is not acceptable to waive AISC Certification.

Date: 1-26-22

By: Chanel Duarte - Stantec Structural



Pre-Bid REQUEST FOR INFORMATION

RFI No:	6
Date:	01/25/22

Submitted to: City of Fresno	Submitted By: David Silva
Attention: Sandra Gamez	E-mail: estimating@amgassociatesinc.com
Phone: 661-251-7401	Fax: 661-251-7401

Project:	Fresno Area Express Facility Improvement	Spec. Section:	122113
Location:		Drawing #:	
Sent Via	Email	Detail:	

The following information is requested:

Please provide location where horizontal louver blinds will be install?

Response:

[Rooms with miniblinds are specified in the Room Finish Schedule under Remarks - refer to schedule on Sheet A-600.](#)

[- Jiah Hong, Stantec 1/25/2022](#)



Pre-Bid REQUEST FOR INFORMATION

RFI No:	7
Date:	01/25/22

Submitted to: City of Fresno	Submitted By: David Silva
Attention: Sandra Gamez	E-mail: estimating@amgassociatesinc.com
Phone: 661-251-7401	Fax: 661-251-7401

Project:	Fresno Area Express Facility Improvement	Spec. Section:	105113
Location:		Drawing #:	
Sent Via	Email	Detail:	

The following information is requested:

We couldn't find a cut sheet for a single tier locker, please provide or a model number.

Response:

[Refer to Spec Section 10 51 13 Metal Lockers for products that may be incorporated into the project.](#)

- Jiah Hong, Stantec 1/25/2022