



**BAKERSFIELD OFFICE**

1200 DISCOVERY DR. 160 | BAKERSFIELD, CA 93309  
661.843.8400 T | 661.843.8448 F  
ARCHITECTS ENGINEERS CONNECTED

**ADDENDUM NO. 04**

**PROJECT:**

**College of the Sequoias  
Tulare Campus CTE**  
4999 Bardsley Avenue  
Visalia, CA 93274

Date: **12/16/2022**

TETER Project No.: **21-12032.00**

**CLIENT:**

**College of the Sequoias**  
915 S. Mooney Blvd.  
Visalia, CA 93277

Client Project No.: **N/A**

DSA File No.: **54-C2**

DSA Appl. No.: **02-120265**

*The following additions, deletions and revisions to the plans, specifications and Addenda shall become a part of the plans and specifications. It is the responsibility of the General Contractor to submit the information contained in this addendum to all subcontractors and suppliers. The Bidder shall acknowledge receipt of the Addendum in the Bid Proposal.*

**Pre-Bid RFI Responses:**

1. Specification 28 00 00 was just issued for the Tulare COS Campus. It calls for the contractor to provide intrusion devices and cameras for the project, but no manufacturers or part numbers are referenced. The original plans call for rough-in only.
  - a. GC to provide rough in only as shown/noted on plans. Intrusion devices and cameras are OFOI.

**END OF ADDENDUM NO. 04**

Jon Coulter  
Architect of Record

Attachments:

- Substitution Request Form – Fire Alarm



TETER, LLP  
ARCHITECTS ENGINEERS CONNECTED

SUBSTITUTION REQUEST FORM

FOR: COS Tulare Campus CTE

We hereby submit for your consideration the following product instead of the specified item for the above project:

SECTION	PARAGRAPH	SPECIFIED ITEM
<u>FIRE ALARM DRAWINGS</u>		<u>GAMEWELL-FCI E3</u>

Proposed Substitution: FIKE FCP-300ECS.

Attach complete technical data, including laboratory tests, if applicable.

Include complete information on changes to Drawings and/or Specifications which proposed substitution will require for its proposed installation.

Fill in the blanks below:

- A. Does the substitution affect dimension on Drawings:  
NO
- B. Will the undersigned pay for changes to the building design, including engineering and detailing costs caused by the requested substitution?  
NO
- C. What affect does substitution have on other trades?  
NONE
- D. Difference between proposed substitution and specified item?  
SAME FUNCTIONALITY
- E. Manufacturer's guarantees of the proposed and specified items are:  
 Same  Different (explain on attachment)
- F. Cost difference between proposed substitution and specified item - savings to Owner?  
UNKNOWN.

The undersigned states that the function, appearance and quality are equivalent or superior to the specified item and will be at no additional cost to the Owner.

Submitted to the Architect by:

Signature: [Signature]

For Use by Design Consultant

Firm: DIGITECH INTEGRATION INC.

Accepted \_\_\_\_\_  
 Accepted as Noted X  
 Not Accepted \_\_\_\_\_  
 Received Too Late \_\_\_\_\_

Address: 104 E. GTH ST.  
HANFORD, CA, 93230

Date: 12-5-2022

By: BRYAN GLASS, ELECTRICAL ENGINEER/PARTNER

Telephone: (559) 582-2300

Date: 12/16/2022

Remarks: \_\_\_\_\_

ACCEPTANCE IS CONTINGENT ON REVIEW OF CONTRACTORS COMPLETE FIRE ALARM SUBMITTAL PER DSA REQUIREMENTS INCLUDING SHOP DRAWINGS, CUT SHEETS, AND CSFM LISTING TO CONFIRM THAT THE PROPOSED SYSTEM IS EQUAL TO THE SYSTEM SPECIFIED