



**HOWE Electric**  
Construction, Inc.  
License # 898737 Class B, C10, C46

## Request For Direction

RFD Number: 002

To: Kitchell Corporation  
\_\_\_\_\_  
\_\_\_\_\_

Date: 05/18/23  
Project Name: Shields & Brawley Elementary School

Attn: Luz Gonzalez

Priority: ☐ Normal ☒ Expedite ☐ Urgent

## Request Due To:

<input checked="" type="checkbox"/> Direction Not Given In Contract Documents	Drawing Reference: <u>E2.2</u>
<input type="checkbox"/> Interpretation of Contract Documents	
<input type="checkbox"/> Conflict in Contract Documents	Specification Reference: _____

Subject: **Size For PG&E Pull Box**

Key Note #2, Drawing E2.2 identifies a proposed PG&E pull box and states in part *"...Pull hole per PG&E Rules"*, however the pull box size is not indicated. Please provide required size of PG&E pull box. - Thank You

Submitted	Possible Cost	Possible Time
By: <u>Nick Brown</u>	Impacts: <u>unknown</u>	Impacts: <u>unknown</u>

## Reply:

Keynote 2 is a proposed pull box/hole location. Actual PG&E service conduits and substructures shall be per the Rule 16 documents. My understanding is these have been issued.  
Scott D. HDE 5/22/23

Reply

By: \_\_\_\_\_ Date: \_\_\_\_\_