

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 13

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: A2.3, A8.14 Spec. Section: _____

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

Window Type D, A2.3 is an aluminum storefront window but the details on the schedule are 261, 265, 267/A8.14 which are for fiberglass windows. Type D is too big to build in fiberglass and we assume the aluminum storefront material call-out is correct. Please correct details to reflect aluminum storefront, not fiberglass windows.

RESPONSE:

response:


not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

The design intent is for type D window to be aluminum storefront window in lieu of fiberglass window

in lieu of detail 265/ A8.14 2, replace with detail 90/A8.5 (Storefront Window HEAD)

in lieu of detail 265/ A8.14 2, replace with detail 91/A8.5 (Storefront Window JAMB)

in lieu of detail 265/ A8.14 2, replace with detail 92/A8.5 (Storefront Window SILL)

 5.22.23

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received _____ am