

REQUEST FOR INFORMATION**DORFMEIER MASONRY INC.**

4685 E. Hedges Ave.
Fresno, Ca. 93703

Phone: (559) 255-9760

Fax: (559) 252-5508

PROJECT:	Sheilds & Brawley ES	RFI #:	1
TO:	Kitchell Corporation	DATE:	5/22/2023
		REPLY BY:	
		SPECS:	
Email:	lgonzalez@kitchell.com	PLANS:	
DMI JOB #		TIME IMPACT	
		COST IMPACT	

Detail A/A8.12 shows that the field CMU is split face A-81. Is the A-81 CMU at the Service Yard and Break Room Patio at the Multi-Purpose Room split face 1 sides or 2 sides?

PREPARED BY:	Wendi Jensen	DATE:	5/22/2023
--------------	--------------	-------	-----------

RESPONSE:**response:**

design intent for Service Yard (single exterior only split-face) & Staff Lounge outdoor Patio (exterior and interior split-face).

if material is NOT available the architect may entertain one side (exterior) only.

 5.23.23