



**HOWE Electric**  
Construction, Inc.  
License # 898737 Class B, C10, C46

**Kitchell RFC 033**  
**Request For Direction**

RFD Number: 007

To: Kitchell Corporation  
\_\_\_\_\_  
\_\_\_\_\_

Date: 05/18/23  
Project Name: Shields & Brawley Elementary  
School

Attn: Luz Gonzalez

Priority: ☐ Normal ☒ Expedite ☐ Urgent

Request Due To:

<input type="checkbox"/> Direction Not Given In Contract Documents	Drawing Reference: <u>E2.2</u>
<input checked="" type="checkbox"/> Interpretation of Contract Documents	
<input type="checkbox"/> Conflict in Contract Documents	Specification Reference: _____

**Subject: Relocatable Building Electrical Work**

Key Note #26, Drawing E2.2 indicates reconnection of relocatable building sections separated prior to transport. Please confirm these reconnections will be provided for by the relocatable building provider. In addition, key note also indicates to provide interior improvements per detail 10/E0.6. Please confirm relocatable building manufacture will provide all in-wall rough-in. - Thank You

Submitted	Possible Cost	Possible Time
By: <u>Nick Brown</u>	Impacts: <u>unknown</u>	Impacts: <u>unknown</u>

**response**

All relocatable classroom buildings shall be deleted from scope of work until further notice.

**CLARIFICATION: FUTURE RELOCATABLE BUILDINGS**

TWELVE (12) 24 x 40 (west campus); FIVE (5) 24 x 40 (east campus), ONE (1) 36 x 40 (pre-school).

Contractor shall provide and install all underground infrastructure for these future portable buildings (including but not limited to power, low-voltage, fire sprinklers (if applicable), fdc, piv, riser connection, etc.)

 5.24.23