

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 14

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: A2.3, A8.6 Spec. Section: _____

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

Window type A, A2.3 is shown with a standard sill member, but the sill detail noted on the schedule (106/A8.6) shows a special height 10" sill profile. This 10" sill profile will add significant additional cost and will be subject to dings/dents/abuse at its ground-floor lobby location. Please confirm that the sill is to be a standard 2" member as indicated on the elevations. In the absence of further direction, Atascadero Glass will assume 2" unless notified otherwise by architect or CM.

RESPONSE:

response:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

The design intent needs to be higher than two inches what is the alternative in lieu of 10 inches, please provide

 **5.22.23**

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received _____ am