

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 18

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: _____ Spec. Section: 05 40 00

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

Specs 05 40 00 Item 2.07 E/3.01B call for Closed-cell Neoprene Foam ¼” on the bottom and rim of track members.

No Detail in the plans for the locations occurs.

Does this apply to all walls, or just exterior walls?

(From David Silva, Estimator AMG Associates)

RESPONSE:

response:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

Spec SECTON 05 40 00, PART 2, 2.07, E reads, Sealer Gaskets: Closed-cell neoprene foam, 1/4 inch thick, selected from Manufacture's standard widths to match width of bottom track **OR** rim track members in lieu of **AND** as stated in the question above.

refer to PART 1, 10.01, A

 5.22.23

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received: _____ am