

Kitchell RFC 46



Karsyn Construction Inc.
4697 W. Jacquelyn Ave.
Fresno, Ca. 93722

PH: 559.271.2900
FX: 559.271.2908

REQUEST FOR INFORMATION

RFI #: 1
GC RFI#:
DATE: 5/23/2023
PHONE:
FAX:

TO:	Kitchell Corporation	REASON FOR REQUEST	ACTION REQUESTED	PROBABLE EFFECT
ATTN:	Luz Gonzales	INSUFFICIENT INFORMATION	CLARIFICATION	INCREASE COST
		ENGINEERING CONFLICT	DIRECTION	DECREASE COST
		ALTERNATE PROPOSAL	APPROVAL	UNKNOWN COST
PHONE:	559.271.2900	RESPONSE REQUIRED BY:		INCREASE TIME
FAX:	559.271.2908			DECREASE TIME
FROM:	Jason Coronado			UNKNOWN

REFERENCE: Shields & Brawley E.S.

DRAWING #:

SPECIFICATION #: 092236.23 & 092400

SUBJECT: Metal Lath

INFORMATION NEEDED:

Both specification sections 092236.23 & 092400 mention metal lath.

Please clarify if specification 092236.23 applies to this project.

If so, please clarify which specification to use for metal lath requirements.

RECOMMENDATION:

response:
omit 09 22 36.23 METAL LATH SECTION.
refer to 09 24 00 CEMENT PLASTERING SECTION

5.23.23