

Kitchell RFC 49



Karsyn Construction Inc.
4697 W. Jacquelyn Ave.
Fresno, Ca. 93722

PH: 559.271.2900
FX: 559.271.2908

REQUEST FOR INFORMATION

RFI #: 4
GC RFI#:
DATE: 5/23/2023
PHONE:
FAX:

TO:	Kitchell Corporation	REASON FOR REQUEST	ACTION REQUESTED	PROBABLE EFFECT
ATTN:	Luz Gonzales	INSUFFICIENT INFORMATION	CLARIFICATION	INCREASE COST
		ENGINEERING CONFLICT	DIRECTION	DECREASE COST
		ALTERNATE PROPOSAL	APPROVAL	UNKNOWN COST
		RESPONSE REQUIRED BY:		INCREASE TIME
PHONE:	559.271.2900			DECREASE TIME
FAX:	559.271.2908			UNKNOWN
FROM:	Jason Coronado			

REFERENCE: Shields & Brawley E.S.

DRAWING #: A8.6/114

SPECIFICATION #: 9300

SUBJECT: Tile Substrate

INFORMATION NEEDED:

Specification section 09300 indicates options for solid backing for wall tile installation. Options include plaster, wood, masonry or gypsum board.

Detail 114 on A8.6 shows cementitious backer units behind wall tile.

Please clarify which substrate for wall tile is to be used on this project.

RECOMMENDATION:

response:

Substrate wall tile material, provide WATER RESISTANT GYP. BOARD in lieu of cementitious backer board

5.25.23