

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 012

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: A2.3, A2.6, A8.5, Spec. Section: _____

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

1. Window Type A (A2.3) and Window Types A, D, E (A2.6) exceed the manufacturer's wind load performance limitations for center-glazed storefront which is detailed in Det. 90, 91, 92/A8.5. Systems will need to be curtainwall. Given heights and tributary areas of Type E, please review the wind load charts below and confirm if window types A, D, E should be bid as 7 ½" or 10 ½" curtainwall.

SEE ATTACHED KAWNEER 1600 SERIES 10" & 7 ½" CURTAINWALL:

RESPONSE:

reponse:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

Sheet T2, architectural notes, deferred items, 2: This question is a DSA deferred item. Contractor responsible for it's OWN window engineer to decipher thickness of currentwall to be acceptable to DSA.

 5.22.23

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received _____ am