

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 006

FIRM NAME: ATASCADERO GLASS DATE: May 16, 2023

SENDER/CONTACT NAME: SHANE PAYTON e-MAIL: spayton@atascaderoglass.com

MAILING ADDRESS _____

BUSINESS PHONE: 805.466.2644 x24 CELL NO: 805.674.5074

DWG. No.: Addendum 01 Spec. 08 87 13
Section: _____

QUESTION: *(Type or print question in the space provided. Attach sketches if necessary.)*

Question from ATASCADERO GLASS:

Solar Control Film was added in Addendum #1 via Section 08 87 13. Please confirm:

- a. What type of tint film is required for this project. 08 87 13 lists a manufacturer but no material type; 3M offers numerous applied tint films.
- b. Where does the tint film occur (which window #'s)?

Garry Clark
Project Superintendent, Kitchell

RESPONSE:

response:

- a. opaque film material, provide THREE (3) standard material type during submittal review.
- b. intention are all restroom exterior windows for trade to provide & install solar control film, on 1st or 2nd floor. notify architect immediately of a window was missed.

MAIN BLDG:

1st floor: 106; 107; 116; 117
2nd floor: 224; 225

MPR BLDG:

308; 309; 310; 311


05/18/2023

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received: _____ am