

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 8

e-Mail form to lgonzalez@kitchell.com

RFC No. 002

FIRM NAME: Kitchell DATE: May 5, 2023

SENDER/CONTACT NAME: Garry Clark e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 FAX NUMBER: _____

DWG. No.: E2.2 Spec. Section: 26 00 00

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

Situation:

Keynote 1 on E2.2 indicates the point of connection for primary power will be at an existing power pole along North Brawley Avenue.

Question:

Will the Addendum 01 drawings clarify that the existing overhead power distribution will be undergrounded. Also will the drawings indicate the revised point of connection?

RESPONSE:

DRAFT Response from Garry Clark:

PG&E Construction sketches show the location and details for the planned connection for primary power.

These PG&E drawings for this off-site work will be included in an addendum.

5.22.23

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received _____ am

This form may be removed from the project specifications and/or reproduced as needed.