

Kitchell RFC 50



Karsyn Construction Inc.
4697 W. Jacquelyn Ave.
Fresno, Ca. 93722

PH: 559.271.2900
FX: 559.271.2908

REQUEST FOR INFORMATION

RFI #: 5
GC RFI#:
DATE: 5/23/2023
PHONE:
FAX:

TO:	Kitchell Corporation	REASON FOR REQUEST	ACTION REQUESTED	PROBABLE EFFECT
ATTN:	Luz Gonzales	INSUFFICIENT INFORMATION	CLARIFICATION	INCREASE COST
		ENGINEERING CONFLICT	DIRECTION	DECREASE COST
		ALTERNATE PROPOSAL	APPROVAL	UNKNOWN COST
		RESPONSE REQUIRED BY:		INCREASE TIME
PHONE:	559.271.2900			DECREASE TIME
FAX:	559.271.2908			UNKNOWN
FROM:	Jason Coronado			

REFERENCE: Shields & Brawley E.S.

DRAWING #: A8.10/190

SPECIFICATION #:

SUBJECT: 1" Dens. Glass

INFORMATION NEEDED:

Detail 190 on A8.10 indicates "1" DENS. GLAS" at exterior wall. Densglass does not come in 1" thickness.

Please clarify if 1" is required at this location. If so, please clarify if 1" shaftliner or (2) layers of 1/2" exterior sheathing will be required.

response:

113/A8.6 119/A8.6 calls out for Dens-Glas GOLD. Architect would have to check on Title 24 Compliance. contractor to bid TWO (2) LAYERS OF 1/2" dens-glas GOLD.

5.25.23