

**DOCUMENT 00110**  
**CONTRACTOR REQUEST FOR CLARIFICATION**  
**PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2**

e-Mail form to [lgonzalez@kitchell.com](mailto:lgonzalez@kitchell.com)

**RFC No. 19**

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS \_\_\_\_\_

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: \_\_\_\_\_ Spec. Section: 09 29 00 Gyp Board

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

Spec 09 29 00 Gypsum Board 2.02C calls for the use of Silent Noise Reducing Gypsum Board to occur at the common walls adjacent to each other: C105, C110, C113 ... No C Rooms exist.

Please provide locations for this product.

(From David Silva, Estimator AMG Associates)

RESPONSE:

**response:**

**not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.**

**Spec SECTION 09 29 00, PART 2, 2.02, C: omit all references to SilentFX Noise-Reducing Gypsum Board.**

 **5.22.23**

Response by: \_\_\_\_\_ Date: \_\_\_\_\_

Included in Addenda No. \_\_\_\_\_ Date: \_\_\_\_\_

Date Received: \_\_\_\_\_ Time Received: \_\_\_\_\_ am

