



**HOWE Electric**  
Construction, Inc.  
License # 898737 Class B, C10, C46

## Request For Direction

RFD Number: 010To: Kitchell CorporationDate: 05/23/23Project Name: Shields & Brawley Elementary SchoolAttn: Luz GonzalezPriority: ☐ Normal ☒ Expedite ☐ Urgent

## Request Due To:

<input type="checkbox"/> Direction Not Given In Contract Documents	Drawing Reference:	
<input checked="" type="checkbox"/> Interpretation of Contract Documents	Specification Reference:	<u>Addendum #1</u>
<input type="checkbox"/> Conflict in Contract Documents		<u>Electrical SOW</u>
		<u>BP8</u>

Subject: **Future Marquis Signs**

Addendum #1, Electrical Scope of Work for Bid Package #8, Inclusions Item #53, states in part to furnish low voltage for mechanical equipment, while Addendum #1, Mechanical Scope of Work for Bid Package #7, Item #13, states in part to furnish conduit pathways and wiring requirements for HVAC controls and elsewhere as applies. Please confirm all mechanical controls shall be provided for under Mechanical, Bid Package #7. - Thank You.

## response:

do not understand subject title or mention of Marquee sign. do not understand electrical, mechanical, HVAC controls concerns. if the response from Kitchell has answered the question sorry for the confusion. However the Marquee has been relocated (further to the east) closer to Brawley Ave and contractor to install conduits for power and low-voltage underground infrastructure.

Submitted

By: Nick BrownImpacts: unknownImpacts: unknown

05/24/2023

## Reply:

I DID NOT SEE ANYTHING ABOUT LOW VOLTAGE IN ITEM 53 HOWEVER IT IS CORRECT THAT SB 7 MECHANICAL WILL BE RESPONSIBLE FOR PROVIDING CONDUIT PATHWAYS AND WIRING REQUIREMENTS FOR HVAC CONTROLS

Reply

By: Gary Clark KITCHELL

Date: \_\_\_\_\_