

KITCHELL RFL 60



HOWE Electric
Construction, Inc.
License # 898737 Class B, C10, C46

Request For Direction

RFD Number: 011

To: Kitchell Corporation

Date: 05/23/23
Project Name: Shields & Brawley Elementary
School

Attn: Luz Gonzalez

Priority: ☐ Normal ☒ Expedite ☐ Urgent

Request Due To:

<input type="checkbox"/> Direction Not Given In Contract Documents	Drawing Reference:	<u>LS.1.0</u>
<input checked="" type="checkbox"/> Interpretation of Contract Documents	Specification Reference:	<u>Addendum #1</u>
<input type="checkbox"/> Conflict in Contract Documents		<u>Electrical SOW</u>
		<u>BP8</u>

Subject: Landscape Control Conduit & Wiring

Addendum #1, Electrical Scope of Work for Bid Package #8, Inclusions Item #¹⁸~~16~~, states in part to "Install electrical/low voltage and final terminations required for landscaping / irrigations scopes...Reference Landscape drawings for electrical scope". Please confirm low voltage control conduits and wiring (example: Drawing LS.1.0, Irrigation Notes #6 and #13) shall be furnished and installed by landscape contractor. - Thank You.

Submitted	Possible Cost	Possible Time
By: <u>Nick Brown</u>	Impacts: <u>unknown</u>	Impacts: <u>unknown</u>

Reply:

ITEM 18 IN BID PAC 8 WILL BE MODIFIED TO
DELETE "LOW VOLTAGE AND FINAL TERMINATIONS"
AND CLARIFY THAT BID-PAC 8 WILL PROVIDE POWER
REQUIRED.
THIS CONFIRMS THAT LOW VOLTAGE CONTROLS, CONDUITS &
WIRING WILL BE PROVIDED BY THE LANDSCAPE CONTR.

Reply

By: Samy Cloud

Date: 5/23/2023