

**DOCUMENT 00110**  
**CONTRACTOR REQUEST FOR CLARIFICATION**  
**PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2**

e-Mail form to [lgonzalez@kitchell.com](mailto:lgonzalez@kitchell.com)

**RFC No. 22**

FIRM NAME: KITCHELL DATE: May 18, 2023

SENDER/CONTACT NAME: Garry Clark e-MAIL: gclark@kitchell.com

MAILING ADDRESS \_\_\_\_\_

BUSINESS PHONE: 559.288.3712 CELL NUMBER: SAME

DWG. No.: C2.1, C6.9 Spec. Section: Division 2 CMU Masonry

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

What is the **color and texture** of CMU for the 6' Block wall along the West property line?

Is it to be the **same pattern as the service yard?**

RESPONSE:

response;  
precision Type CMU and radius concrete cap with City of Fresno, Public Works detail P-93, C (off-set 12" footing) Wall Section. Paint wall on school side (Navajo White). Residential wood fencing to remain.

 5.24.23

Response by: \_\_\_\_\_ Date: \_\_\_\_\_

Included in Addenda No. \_\_\_\_\_ Date: \_\_\_\_\_

Date Received: \_\_\_\_\_ Time Received \_\_\_\_\_ am