

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 011

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: _____ Spec. Section: _____

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

No NRCC-PRF-01-E Form was included with the bid plans to provide whole system Title 24 performance values for the aluminum storefront system. Please provide this form for the project or specify what performance values are required.

RESPONSE:

response:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

contractor to refer to page 2 of 2

 5.22.23

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received _____ am

PBK / LEAF Engineers Respoinsē:\

Refer to Energy Compliance sheet EC5, at lower left for Fenestration Assembly Summary of Glazing. Also refer to T-24 book page 8.

Values per below.

Project Name:	Shields and Brawley ES - Main Building	NRCC-PRF-01-E	Page 8 of 49							
Project Address:	Main Building Fresno	Calculation Date/Time:	16:17, Tue, May 29, 2018							
Compliance Scope:	NewComplete	Input File Name:	18-1024 Shields and Brawley ES Main Building v7 with LTG.cibd16x							
J. FENESTRATION ASSEMBLY SUMMARY								§ 110.6	Confirmed	
1.	2.	3.	4.	5.	6.	7.	8.	9.	Pass	Fail
Fenestration Assembly Name / Tag or I.D.	Fenestration Type / Product Type / Frame Type	Certification Method¹	Assembly Method	Area ft²	Overall U-factor	Overall SHGC	Overall VT	Status²		
PPG Sungate 500 Bronze	VerticalFenestration FixedWindow N/A	NFRC Rated	Manufactured	3212	0.27	0.30	0.50	N	<input type="checkbox"/>	<input type="checkbox"/>
Door Glass	VerticalFenestration GlazedDoor N/A	NFRC Rated	SiteBuilt	294	0.27	0.30	0.50	N	<input type="checkbox"/>	<input type="checkbox"/>
Skylight Glass	Skylight FixedWindow N/A	NFRC Rated	Manufactured	998	0.29	0.27	0.50	N	<input type="checkbox"/>	<input type="checkbox"/>

¹ Newly installed fenestration shall have a certified NFRC Label Certificate or use the CEC default tables found in Table 110.6-A and Table 110.6-B. Center of Glass (COG) values are for the glass-only, determined by the manufacturer, and are shown for ease of verification. Site-built fenestration values are calculated per Nonresidential Appendix NA6 and are used in the analysis.

² Status: N - New, A - Altered, E - Existing