

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 005R1

FIRM NAME: ATASCADERO GLASS DATE: May 23, 2023

SENDER/CONTACT NAME: SHANE PAYTON e-MAIL: spayton@atascaderoglass.com

MAILING ADDRESS _____

BUSINESS PHONE: 805.466.2644 x24 CELL NO: 805.674.5074

DWG. No.: D,P,Q,/A2,3 & A,D,E/A2.6 Spec. 08 80 00
Section: _____

QUESTION: *(Type or print question in the space provided. Attach sketches if necessary.)*

Question from ATASCADERO GLASS:

1. Window Types D,P,Q/A2.3 and A,D,E/A2.6 have shading with the note “Cross Hatch Indicates Spandrel Glass”. No spandrel make-up is listed on the plans or in the glazing spec section 08 80 00. Is spandrel glass required as shown on the window schedule elevations and types listed above? If so, what type and color is required?
2. Please provide specs for Spandrel Glass.

Garry Clark
Project Superintendent, Kitchell

RESPONSE:

response:

1. This is a duplicate question
Spandrel Guardian Glass is required: match as close to low-E, PPG solarban 70 glazing color, cermic brick.

Only note as mentioned above noted "Cross Hatch indicates Spandrel Glass.

2. Provide the following or approved equal

Reflected Coated Vision Glass ASTM C1376:

1. Cermamic Coated Sprandrel Glass:

- a. ASTM C1048, Condition B (spandrel glass, one surface ceramic coating) type 1 (transparent glass flat), Quiality q3 (glazing select), Class 1 (clear), with ceramic coating applied to second surface and complying with the following

requirements:

- 1) Class 1 (clear).
- 2) Class 2 (Tinted, Heat absorbaing and light reducing)
 - a) Tint Color: Matches Solorban 70
 - b) Kind HS (heat strengthened); Kind FT (fully tempered)
 - c) Coating Location: Second surface
 - d) Ceramic Coating Color: Selected by Architect from manufacture's full range

 5.24.23