

**DOCUMENT 00110**  
**CONTRACTOR REQUEST FOR CLARIFICATION**  
**PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2**

e-Mail form to [lgonzalez@kitchell.com](mailto:lgonzalez@kitchell.com)

**RFC No. 15**

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS \_\_\_\_\_

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: A8.5 Spec. Section: \_\_\_\_\_

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

1. Window details for fiberglass windows A8.5 show operable windows, but window schedule does not denote operable window configurations. Please denote operable configuration on the window schedule elevations if any windows are required to be operable. Absent window elevation notation, we will assume all windows are fixed.

RESPONSE:

response:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

in scope of work, no OPERABLE WINDOWS, all windows to provide and install to be FIXED per Title 24.

 5.22.23

Response by: \_\_\_\_\_ Date: \_\_\_\_\_

Included in Addenda No. \_\_\_\_\_ Date: \_\_\_\_\_

Date Received: \_\_\_\_\_ Time Received: \_\_\_\_\_ am