

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 20

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: A7.2 Section F (fire rated Spec. Section: assembly)

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

Sheet A7.2 Section F Corridor 155 & 201 detail 101/109 on A8.63 call for the fire rated ceiling in the corridor.

No other sections reference these details.

Please clarify the locations for this detail.


(From David Silva, Estimator AMG Associates)

RESPONSE:

response:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

corridors 155; 157; 158; 201 running east to west or north to south to be fire rated corridors. notify architect immediately if trades finds architect has missed a corridor.

 5.22.23

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received _____ am