

**DOCUMENT 00110**  
**CONTRACTOR REQUEST FOR CLARIFICATION**

**PROJECT: Central Unified School District – Shields & Brawley Bid Package No.   2**

e-Mail form to [lgonzalez@kitchell.com](mailto:lgonzalez@kitchell.com)

**RFC No.   025**

FIRM NAME: Ceiling Experts Inc. DATE:   5/18/2023  

SENDER/CONTACT NAME: Alex Shatokhin e-MAIL: alex@ceilingexpertsinc.com

MAILING ADDRESS   1340 Main Ave, Sacramento, CA 95838  

BUSINESS PHONE:   916-527-8007   CELL NUMBER:   916-559-4386  

DWG. No.: \_\_\_\_\_ Spec. Section:   095113 Acoustical Panel Ceilings  

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

Spec Section 095113, 2.02.C 1.b calls for BLACK Ultima High-NRC at Stage.  
Our Armstrong rep says that Armstrong doesn't make Ultima High-NRC in BLACK.  
The closest tile to Ultima High-NRC that can be in BLACK is Calla (2x4' - #2821BK, 2x2' - #2820BK).  
Please clarify which one to choose.

RESPONSE:

response:  
The design intent is to have it as the darkest color as possible, prefer 2 x 4 grid and tile.

 5.22.23

Response by: \_\_\_\_\_ Date: \_\_\_\_\_

Included in Addenda No. \_\_\_\_\_ Date: \_\_\_\_\_

Date Received: \_\_\_\_\_ Time Received \_\_\_\_\_ am