

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 17

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: Garry Clark e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: A2.7 Spec. Section: _____

QUESTION: *(Type or print question in the space provided. Attach sketches if necessary.)*

Window #306, A2.7 is called out on the window schedule as a fiberglass nail-on window (Window Type G, Material Type FG). Window details referenced on the window schedule show hollow metal frame with glass. HM frame w/glass would be typical for interior installation rather than fiberglass nail-on. Please confirm that Window #306 is hollow metal.

RESPONSE:

response:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

Window 306 (type E): and door 324 have been relocated to added new kitchen office #314. Do not understand where window Type G came from. Window details 261/A8.14; 265/A8.14; 267/ A8.14 are correct please provide and install.

 5.22.23

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received _____ am