

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 10

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: A6.1, A6.3, F/A7.2, B/A7.1, Spec. Section:
F/A7.2, 158/A8.8

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

Building elevations appear to show integral sunshades at aluminum storefront windows (A6.1, A6.3). Section cut B/A7.1 does not show these sunshades. Section F/A7.2 does show them. Roof plans show a decorative metal awning (Keynote 27), referencing Det. 158/A8.8.

- a. The section cut appears to show an awning attached to a structural member which bisects the window into two (larger lower window and shorter upper window)
- b. Det. 158/A8.8 shows the awning attached to a wall condition w/out any adjacent window.
- c. Window schedule does not show any awnings and does not show the windows segmented into two w/a structural member for awning attachment.

Please confirm that the awnings are not integral with the storefront and that they attach above the window system to the wall, similar to det. 158/A8.8.

RESPONSE:

response:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

Please explain your meaning of sunshades. Garry Clark or original author of this question mentioned decorative metal awnings within the same question. Refer to exterior elevation sheets for counts and locations of decorative metal awnings or dtl. 11/S8.5 you should get a better clarification. I am only guessing on the question. if this is not the case please clarify immediately if this is not the case.

Most of not all decorative metal awnings straddle fiberglass window systems, do not understand statement "at aluminum storefront window" reference.

The windows (approximately 7-feet wide) are not interrupted by the awning supports and straddle window system(s).

 5.22.23

Date Received: _____ Time Received _____ am