

DOCUMENT 00110
CONTRACTOR REQUEST FOR CLARIFICATION
PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2

e-Mail form to lgonzalez@kitchell.com

RFC No. 16

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: Garry Clark e-MAIL: gclark@kitchell.com

MAILING ADDRESS _____

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: A1.3 doors #165 & 167 Spec. Section: _____

QUESTION: *(Type or print question in the space provided. Attach sketches if necessary.)*

A1.3, doors #165 and #167 appear to have sidelights but do not show sidelight window call-outs. Please confirm if these doors have sidelights and if so, confirm the window type.

RESPONSE:

response:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

Door 165 and door 167 to have sidelights and reflect door I/A2.2. Revise door schedule on sheet A.2. to reflect door Type 1 for both. Omit cornerguard from door 167 window

 **5.22.23**

Response by: _____ Date: _____

Included in Addenda No. _____ Date: _____

Date Received: _____ Time Received _____ am