

**DOCUMENT 00110**  
**CONTRACTOR REQUEST FOR CLARIFICATION**  
**PROJECT: Central Unified School District – Shields & Brawley Bid Package No. SB 2**

e-Mail form to [lgonzalez@kitchell.com](mailto:lgonzalez@kitchell.com)

**RFC No. 21**

FIRM NAME: KITCHELL CEM DATE: May 17, 2023

SENDER/CONTACT NAME: GARRY CLARK e-MAIL: gclark@kitchell.com

MAILING ADDRESS \_\_\_\_\_

BUSINESS PHONE: 559.288.3712 CELL NO: same

DWG. No.: \_\_\_\_\_ Spec. Section: 09 29 00

QUESTION: *(Type or print one question in the space provided. Attach sketches if necessary.)*

Abuse Board is called out in the Gypsum Board Specs 09 29 00 2.02H.

Specs or Plans do not clarify its location.

Please provide the locations for this product.

(From David Silva, Estimator AMG Associates)

RESPONSE:

response:

not sure why the firm name and information changed from first SIX (6) pre-bid questions. for future references please provide original trade information.

Spec SECTION 09 29 00, PART 2, 2.02 gypsum board, H: no abuse board & no gymnasium in scope of work.

 5.22.23

Response by: \_\_\_\_\_ Date: \_\_\_\_\_

Included in Addenda No. \_\_\_\_\_ Date: \_\_\_\_\_

Date Received: \_\_\_\_\_ Time Received \_\_\_\_\_ am