

DOCUMENT 00 9111

ADDENDUM NO. THREE

September 17, 2024

COUNTY OF KERN
GENERAL SERVICES

Lamont Park Beautification Project

8304 Segroe Rd. Lamont, CA 93241

1650.7012.22

Item No. 1: Contractor can provide HSS 12"x12"x3/4" with A500 Grade B material with $F_y = 46\text{ksi}$ strength. Refer to specification section 01 6000A for Substitution Request Form.

The following Addenda were issued, modifying the Project Manual:

Addendum No. 3, issued on September 17, 2024.

Addendum No. 2, issued on September 5, 2024.

Addendum No. 1, issued on August 15, 2024.

Alisha Shipe, Contract Specialist
Construction Services Division

Contractor

Signature

Date

Name/Title

END OF DOCUMENT