City of El Monte Q & A for Project Zamora Park Renovation Issued on 09/17/2024 Bid Due on October 16, 2024 1:00 PM (P				
Submitted By KASA Construction, Inc.	Submit Date 09/18/2024 2:02:37 PM	Question Please confirm whether this project is subject to a PLA (Project Labor Agreement), a PSA (Project Stabilization Agreement), a CBA (Collective Bargaining Agreement), a CWA (Community Workforce Agreement), or anything of that nature?	Answer The project is exempt from the City of El Monte's Project Labor Agreement.	Release Date Set Status Addendum #1 - 9/30/2024 Image: Control of the contro
KASA Construction, Inc. KASA Construction, Inc.	09/18/2024 2:02:43 PM 09/18/2024 2:03:14 PM	Is this project subject to State Prevailing Wage Rates OR Federal Davis-Bacon Wage Rates (or both)? Please confirm that the listed Pre-Bid Meeting is Mandatory on 09/25/24 at 8:00 AM.	Both - see Section 1 of RFB for additional information. The pre-bid meeting is mandatory - see Section 1 of RFB for additional information. The basis of award will be the base bid - see Quotation	Addendum #1 - 9/30/2024 Addendum #1 - 9/30/2024
KASA Construction, Inc. KASA Construction, Inc.	09/18/2024 2:03:23 PM 09/18/2024 2:03:30 PM	What is the basis of award? Is an original hard copy of the Bidder's Bond required to be submitted to the agency's office by/before the bid due date and time?	Sheet in RFB for additional information. A Bid Bond is required - see Section 2 of RFB for additional information. Submit electronically through PlanetBids with Contractor's proposal.	Addendum #1 - 9/30/2024 Addendum #1 - 9/30/2024
Los Angeles Engineering, Inc. ARC Construction Inc	09/20/2024 7:00:22 AM 09/24/2024 8:53:54 AM	Is there a project labor agreement or Community Workforce Agreement for this project? DWG Reference: Confirm that PVC SDR-35 can be used for the sewer and storm drain per the plans construction notes #4 and 12.	The project is exempt from the City of El Monte's Project Labor Agreement. Construction Notes 4 and 12 on C4.01 call for SDR 35 PVC pipe.	Addendum #1 - 9/30/2024 Addendum #1 - 9/30/2024
ARC Construction Inc ARC Construction Inc	09/24/2024 8:54:51 AM 09/24/2024 8:56:39 AM	Can a 12" x 12" precast catch basin be used for the curb drain per APWA standard 150-4. Can the existing curb remain in place and only be core drilled for the new curb drain. The existing curb is eight inches. And the new pipe is		Addendum #1 - 9/30/2024 Addendum #1 - 9/30/2024
RJR Water Features	09/26/2024 9:22:45 AM	only four inches. This will save time and money. Will any alternated be considered or accepted for the splash pad amenities? (I.E. the ground sprays & features, activator, and controller).	Substitution requests for splash pad amenities would need to be submitted for review after bid award.	Addendum #3 - 10/7/2024
Ohno Construction Company	09/30/2024 2:49:40 PM	Question: Exhibit H includes several forms which have spaces that designate 'contractor'subcontractor'. Please clarify which, if any, forms in this section are to be submitted by subcontractors being listed at time of bid. If any of these forms are required from subcontractors, we would like to request extra time to turn these in.	Exhibit H forms from subcontractors are not required to be submitted at time of bid, however they will need to be provided before a notice to proceed is issued.	Addendum #3 - 10/7/2024
		Question: Request for Bid, Section 2C #3, requests that a CPM		
Ohno Construction Company	09/30/2024 2:50:27 PM	schedule be submitted with the bid. Since the NTP date is not firm, this schedule will not be accurate. We would like to request that submission of the schedule be made prior to NOIA, or some other point as appropriate, following submission of the bid.	CPM schedule will be required after notice of award.	Addendum #3 - 10/7/2024
			To meet HUD's Section 3 worker and Targeted Section 3 requirements, Contractors can do any of the following to show evidence that outreach efforts were made:	
Los Angeles Engineering, Inc.	10/01/2024 3:44:03 PM	The proposal has HUD Section 3 funds. It notes that we need to reach out to Section 3 subcontractors. However, HUD has shut down the Section 3 database. Does the city have recommendations how to	ragarding racolircac	Addendum #3 - 10/7/2024
		perform outreach to Section 3 businesses, or does the city have a Section 3 list?	Targeted Section 3 definitions 4. Attend Job Fairs 5. Post on website Please note that outreach efforts are highly	
			encouraged throughout the project if the Contractor cannot meet Section3/Targeted Section 3 benchmark hours at the end of the project.	
			See Section 4.1.5. on page 9 of the Request for Bids which states: "Contractor is responsible for Builders Risk Insurance."	
AMG & Associates, Inc.	10/02/2024 10:45:50 AM	Since there is no builder's risk requirements. Please confirm the GC will be included as additional insured in the owner's builder's risk insurance.	See also the Insurance Section of the Rider to A101, starting on page 19 of Exhibit F (Sample Contract) of the Request for Bids which states: "Owner does not intend to obtain property insurance written on a builder's risk 'all risk' or equivalent policy. Contractor	Addendum #3 - 10/7/2024
			must purchase builder's risk 'all risk' or an equivalent policy as Contractor shall be responsible for adequately securing all materials, equipment, and inprogress construction on the Project site."	
			Public Contract Code section 4014 requires bidders on public works projects, at the time of bid submission, to list each subcontractor that will perform more than	
AMG & Associates, Inc.	10/02/2024 4:22:06 PM	A lot of information is required in the list of subcontractors. To save time and reduce errors on the bid forms, would it be acceptable to submit only the name, location, license number and scope of work for each sub and submit the remaining information within 24 hours?	one-half of one percent of the general contractor's work. A contract amount or percentage will be needed to determine the percentage of the work to be completed by the subcontractor.	Addendum #3 - 10/7/2024
			Other information such as the EIN number, estimated start and completion dates can be left blank at the time of submission. Complete as much of the Project Wage Rate Sheet as	
AMG & Associates, Inc.	10/02/2024 4:25:50 PM	What information is supposed to go on the project wage rate sheet? Where can this information be found? Does a CPM schedule need to be provided at the time of bid or can	possible using the applicable federal and state wage determinations. The relevant information can be found at Addendum #2 to the Request for Bid.	
AMG & Associates, Inc. AMG & Associates, Inc.	10/02/2024 4:27:15 PM 10/02/2024 4:30:06 PM	this be submitted after the project is awarded? Is there a form for the Business Tax Registration Certification? Please provide this form?	A Business Tax Registration Certification will not be required for this project.	Addendum #3 - 10/7/2024 Addendum #4 - 10/10/2024
AMG & Associates, Inc.	10/02/2024 4:38:17 PM	What is the City contract number? Does the pricing on the quotation sheet need to be filled out and	Bidders can leave the City Contract Number on the Project Wage Rate Sheet (part of Exhibit G – Forms/ Affidavits to Complete and Submit with Bid) blank.	Addendum #3 - 10/7/2024
AMG & Associates, Inc. AMG & Associates, Inc.	10/02/2024 4:40:15 PM 10/02/2024 4:43:32 PM	uploaded with the documents as well as entered in the line items tab on PlanetBids? This is repeated work.	HUD form 4230A is only required if there will be trades used in the Project that are not identified in the	Addendum #4 - 10/10/2024 Addendum #3 - 10/7/2024
AMG & Associates, Inc. AMG & Associates, Inc.	10/02/2024 4:43:32 PM 10/02/2024 4:47:21 PM	Is the HUD 4230A form supposed to be submitted with the bid? Are there any self-perform requirements for this project?	Federal Wage Decision provided in Exhibit H (as updated by Addendum #2 to the Request for Bid). No, there are no self-perform requirements on the project.	Addendum #3 - 10/7/2024 Addendum #6 - 10/15/2024
AMG & Associates, Inc.	10/02/2024 4:59:54 PM	The Request For Bid Section 2, Letter C, Numbers 7 and 9 are usually provided after the project is awarded. Can they be provided after the project is awarded?	Bidders must submit at time of bid proof of licensing and proof of ability to provide insurance and bonds as noted in the Request for Bids. Insurance coverage and Payment and Performance Bond for the project will not be required until after a contract is awarded.	Addendum #3 - 10/7/2024
			not be required until after a contract is awarded. Builders Risk Insurance is required.	
AMG & Associates, Inc.	10/03/2024 10:39:24 AM	Under Exhibit F page 10 of 12 of AIA form (A101-2017). It mentions that builder's risk coverage is required. Please confirm if builder's risk		Addendum #3 - 10/7/2024
,	J.JJ.Z4 AM	that builder's risk coverage is required. Please confirm if builder's risk coverage is required.	starting on page 19 of Exhibit F (Sample Contract) of the Request for Bids which states: "Owner does not intend to obtain property insurance written on a builder's risk 'all risk' or equivalent policy. Contractor must purchase builder's risk 'all risk' or an equivalent policy as Contractor shall be responsible for adequately securing all materials, equipment, and in-	
AMG & Associates 1	10/03/2024 12	Please consider attached structure cast submittal for the prefabricated restroom. Please advise if this manufacturer is	progress construction on the Project site." Substitution requests for pre-fabricated restroom and	Addendum #6 - 10/15/2024
AMG & Associates, Inc. Fielding Electric Inc.	10/03/2024 10:39:24 AM 10/03/2024 10:40:07 AM	prefabricated restroom. Please advise if this manufacturer is acceptable to use for this project. Unable to access Addendum 2. Can you provide?	trash enclosure vendor would need to be submitted for review after bid award. Addendum #2 is available on the City of El Monte's PlanetBids portal for the Zamora Park Renovation Project under the Addenda/Emails tab.	Addendum #6 - 10/15/2024 Addendum #3 - 10/7/2024
		There are notes listed on panel schedule for existing panel C stating "Circuits controlled by 20A-4Pole mech held relay, photocell on time		
AMG & Associates, Inc.	10/03/2024 11:19:24 AM	"Circuits controlled by 20A-4Pole mech held relay, photocell on time clock off" & "Circuits controlled by 20A-2Pole mech held relay, photocell on time clock off". Are these notes just for reference, or wil the breakers need to be provided and installed in the existing panel? If needed to be provided, please provide panel manufacturer & existing breaker types for existing panel C. To properly quote these breakers to match existing we will need this information.	,	Addendum #4 - 10/10/2024
		Please provide panel manufacturer & existing breaker types for		
AMG & Associates, Inc.	10/03/2024 11:19:24 AM	existing switchboard MS. It is mentioned on the plans that a new breaker will be required, and to properly quote this breaker to match existing we will need this information.	The main 400 amps switchboard manufacture is SYLVANIA	Addendum #4 - 10/10/2024
AMG & Associates, Inc.	10/03/2024 11:19:24 AM	On Civil plan C1.01 it states to protect in place existing concrete basketball court but on Electrical plan E-2.00 it shows an underground conduit run between lights going through the area to be protected. Will this conduit need to be bored under existing concrete or can it be rerouted to avoid the concrete area? If rerouted please provide updated plans showing where to reroute this conduit.		Addendum #6 - 10/15/2024
Marina Landscape Inc.	10/03/2024 11:23:59 AM	Please provide model and detail for the drip air relief valve.	Contractor may provide submittal from either Netafim, Rainbird or Hunter.	Addendum #4 - 10/10/2024
Marina Landscape Inc.	10/03/2024 11:23:59 AM	In reference to sheet L-2.00, the legend shows all the pop-up bodies for the turf area and planters is PRO06-PRS40-CV, while on sheet L-2.10, the detail R requires using I20-06-PRB for the turf area, and the detail N indicated that model Hunter PROS04-PRS30 was for the planter area. Please clarify. The legend for the lateral line on sheet	The legend takes precedence in information over details and specifications for the pop-up irrigation and	Addendum #4 - 10/10/2024
		L-2.00 noted that the lateral line size ranges from 0.75" to 2.5" size, which is standard 40, and 3" size or larger is class 315. However, specisection 328400, part 2.01, documented that all the lateral lines are schedule 40. Please clarify.	lateral pipe.	
Marina Landscape Inc. Marina Landscape Inc.	10/03/2024 11:23:59 AM 10/03/2024 11:23:59 AM	Spare wire pull box isn't shown on irrigation plan. Please clarify. Refer to sheet L-3.12 spec 329000/ 2.03, soil preparation material and rate are difference. Please clarify which one shall be take precedence	Provide a spare wire to the farthest of each mainline leg - (6) total. d Sheet L3.12 takes precedence.	Addendum #4 - 10/10/2024 Addendum #4 - 10/10/2024
Marina Landscape Inc.	10/03/2024 11:23:59 AM	Refer to specs section 329000, mulch product shall be Forest Floor 1/2 to 1-1/2", manufactured by Aguinaga. Refer to note 12/L-3.00, Forest mulch from Tierra Verde Industries. Please clarify.	Either mulch is acceptable.	Addendum #4 - 10/10/2024
Marina Landscape Inc. Marina Landscape Inc.	10/03/2024 11:23:59 AM 10/03/2024 11:23:59 AM	Refer to note 19, root barrier shall be installed for trees within 6' of concrete paving. Please provide the length required for each tree. Refer to detail 3/ C9.01, please provide specification for soil mix material.	Contractor to install at a minimun length of 4'-0" per tree. Contractor to provide Gail Materials bioswale mix or equal.	Addendum #4 - 10/10/2024 Addendum #4 - 10/10/2024
Marina Landscape Inc.	10/03/2024 11:23:59 AM	Please confirm if there is a conflict between the quantity of trees and shrubs shown on the plan with the planting legend. Which one shall be take precedence	The plan takes precedence over the legend Contractor will be responsible for coordinating staging	Addendum #4 - 10/10/2024
Marina Landscape Inc. Marina Landscape Inc.	10/03/2024 11:23:59 AM 10/03/2024 11:23:59 AM	Us there a staging location for materials? Please provide location. Where do subcontractors park their vehicles? Is there any parking fee that subcontractors need to carry in their bid	location within construction limits. Vehicles to utilize street parking. Contractor to	Addendum #6 - 10/15/2024 Addendum #6 - 10/15/2024
California Waters Development, Inc.	10/03/2024 12:56:22 PM	NEC Code 680.13 requires emergency shut off switch to be not less than 5 feet from edge of splash pad. Current plans show location	The location of the EPO as currently specified is "not less then 5 feet from edge of splash pad" meaning it must be located at least 5 feet from the edge of the	Addendum #6 - 10/15/2024
California Waters Development, Inc.	10/03/2024 12:56:22 PM	Please confirm that specified UV system Prominent Dulcodes MP 1x1A 1000Watt for the splash pad meets current NSF50 rating for elimination of cryptosporidum as required per CA building code	splash pad. Specified UV is NSF50 listed	Addendum #6 - 10/15/2024
California Waters Development, Inc.	10/03/2024 12:56:22 PM	Rain diverter detail 1 Sheet SP-2.2 doesn't show footing detail or requirements, please clarify.	Refer to the manufacturers installation instructions for footer recommendations.	Addendum #6 - 10/15/2024
California Waters Development, Inc.	10/03/2024 12:56:22 PM	Please provide deadman anchor system footing for splash pad holding tank as no details are provided for thickness, rebar, concrete rating.	Refer to the tank manufacturers installation instructions for deadman specifications. Alternatively, the specified tank manufacturer has per-fab deadman as an option.	Addendum #6 - 10/15/2024
		No feeting detail provided for Muchroom feature for splach and	Refer to manufacturer for footing specifications.	
California Waters Development, Inc.	10/03/2024 12:56:22 PM	No footing detail provided for Mushroom feature for splash pad, please provide footing detail.	https://www.dropbox.com/scl/fi/do0d89cqpg4bz2lgmw1t2/Mushroom-Footing-Detail.pdf?rlkey=b3shw594ruvy1p1abwy6rbgfa&dl=0	Addendum #6 - 10/15/2024
California Waters Development, Inc.	10/03/2024 12:56:22 PM	Plan sheet Sp3.2 notes a splash pad manifold, there is no mention of manufacturer for the manifold or mentioned of one within the equipment legend on sheet SP1.2. Please clarify. Sheet 3.1 schematic notes what can be assumed to be solenoid valve	The manifold should be provided by the same manufacturer as the spray features.	Addendum #6 - 10/15/2024
California Waters Development, Inc. California Waters Development, Inc.	10/03/2024 12:56:22 PM 10/03/2024 12:56:22 PM	Sheet 3.1 schematic notes what can be assumed to be solenoid valve with "SV", no specification for manufacturer or model number is specified for these valve, please clarify. No specifications are provided for splash pad valves, please provide specification and clarify manufacturer and model.	The solenoid valve for the auto fill system comes with the autifill controller. Spears valves, NSF 50 listed.	Addendum #6 - 10/15/2024 Addendum #6 - 10/15/2024
California Waters Development, Inc. California Waters Development, Inc.	10/03/2024 12:56:22 PM 10/03/2024 12:56:22 PM			Addendum #6 - 10/15/2024 Addendum #6 - 10/15/2024
California Waters Development, Inc. California Waters Development, Inc.	10/03/2024 12:56:22 PM 10/03/2024 12:56:22 PM	Sheet SP-3.2 notes piping sizing but is unclear which lines are 2.5" and which lines are the 2" please clarify. Main drain piping on sheet SP-3.2 does not provide sizing of pipe to rain diverter or from rain diverter, please clarify pipe sizing.	Refer to 1/SP3.1 for pipe specifications Refer to 1/SP3.1 for pipe specifications	Addendum #6 - 10/15/2024 Addendum #6 - 10/15/2024
California Waters Development, Inc. California Waters Development, Inc.	10/03/2024 12:56:22 PM 10/03/2024 12:56:22 PM	Please clarify color for splash pad activator bollard. Please clarify depth of splash pad holding tank (detail 2 SP-2.2) to finished grade, this will be needed to determine the length of manhole extension when getting equipment quote.	TBD by Client. Not applicable to bid. This needs to be varified in-field based on location of rain diverter but approx. 36" top of tank to grade for bid purposes.	Addendum #6 - 10/15/2024 Addendum #6 - 10/15/2024
California Waters Development, Inc. California Waters Development, Inc.	10/03/2024 12:56:22 PM 10/03/2024 12:56:22 PM	Please clarify if splash pad holding tank (detail 2 SP-2.2) is to be flush with grade or how far above finished grade is required. Rain diverter on sheet SP-2.2 detail 1 notes "hatch sold separately". Please clarify manufacturer and model for compatible hatch	Top of lid approx. 6" above grade. Bilco type J-AL 30"x30"	Addendum #6 - 10/15/2024 Addendum #6 - 10/15/2024
California Waters Development, Inc.	10/03/2024 12:56:22 PM	Geotechncal report for Boring location 3 which is the approximate splash pad location only reaches depths of 4 feet splash pad holding tank and associated excavation will exceed this depth please clarify assumptions to be made by bidder during excavation and installation	For bidding purposes; follow recommendations as provided within current geotechnical report. Geotechnical Engineer to provide open hole observation to verify.	Addendum #6 - 10/15/2024
California Waters Development, Inc.	10/03/2024 12:56:22 PM	of this element. Please provide installation or mounting detail for emergency stop for splash pad no details provided for method of installation.	observation to verity.	Addendum #6 - 10/15/2024
California Waters Development, Inc. California Waters Development, Inc.	10/03/2024 12:56:22 PM 10/03/2024 12:56:22 PM	Please confirm there are no Division 13 special construction specifications for the splash pad, no specifications provided for splash pad construction within bid documents. Structural note 9 on sheet SP-1.0 notes "shotcrete". Use of shotcrete is not recommended for structural flat work of splash pad footings or	·	Addendum #6 - 10/15/2024 Addendum #6 - 10/15/2024
California Waters Development, Inc. California Waters Development, Inc.	10/03/2024 12:56:22 PM 10/03/2024 12:56:22 PM	Please clarify the manufacturer for the splash pad controller, there are multiple vendors providing products for this splash pad it is unclear who the controller is to be sourced from.	Total Control (Designed by Landrec)	Addendum #6 - 10/15/2024 Addendum #6 - 10/15/2024
California Waters Development, Inc.	10/03/2024 12:56:22 PM	Please confirm that plan set has been submitted and approved for construction with city building department.	All City of El Monte plan checks have been cleared other than the deferred submittals listed on the plans.	Addendum #6 - 10/15/2024
			The splash pad design and plan check are complete. The contractor shall obtain all permits through City of	
California Waters Development, Inc.	10/03/2024 12:56:22 PM	General note 6 on sheet 43 of 57 SP-1.0 states "Contractor is responsible for obtaining all required permits & inspections". Confirm that any corrections or revisions required during plan check will be performed by designer. This may cause delays as turn around times are unpredictable and contractor has no control of this process.	The contractor shall obtain all permits through City of El Monte Building and Safety and the Los Angeles County Health Department. The contractor is responsible for the coordination of all inspections with both AHJs. If any revisions are made, the design team will be responsible to submit to the AHJ for review and	
California Waters Development, Inc.	10/03/2024 12:56:22 PM	Please confirm that splash pad drawings have been approved for construction by Los Angeles County Department of Health.	Splash pad drawings have been submitted to Los Angeles Department of Public Health and were approved on 11/23/2022 under permit number	Addendum #3 - 10/7/2024
		If current plans for splash pad are not already approved for construction by Los Angeles County health department there may not be enough time to have the submitted, reviewed, revised and	B00-028-0206.	
California Waters Development, Inc.	10/03/2024 12:56:22 PM	be enough time to have the submitted, reviewed, revised and approved for construction and build within the 180 working days. There is no way for the contractor to control the time it take for this process which could take multiple months depending on health department's current backlog. Please clarify that additional duration will be granted based upon when the splash pad construction set is approved for construction.	Splash pad drawings have been submitted to Los Angeles Department of Public Health and were approved on 11/23/2022 under permit number B00-028-0206.	Addendum #3 - 10/7/2024
Ohno Construction Company	10/03/2024 3:06:46 PM	Reference: Restroom Structure Question: Please confirm if there is an approved alternate for the pre-fab restroom and the trash enclosure. We have received feedback that Corworth is not confirmed as being	trash enclosure vendor would need to be submitted	Addendum #6 - 10/15/2024
Ohno Construction Company	10/03/2024 3:08:27 PM	We have received feedback that Corworth is not confirmed as being able to provide a bid in California. Question: Please consider alternative product from Structure Cast – as submitting via email	for review after bid award. Substitution requests for pre-fabricated restroom and trash enclosure vendor would need to be submitted for review after bid award.	Addendum #6 - 10/15/2024
California Waters Development, Inc. California Waters Development, Inc.	10/03/2024 3:09:41 PM	Please clarify color for Mushroom feature for the splash pad, no color noted Plan sheet SP-1.2 notes a concrete sealer for the splash pad finish.	Color TBD by Client. Not applicable to bid.	Addendum #6 - 10/15/2024 Addendum #6 - 10/15/2024
California Waters Development, Inc.	10/03/2024 3:09:41 PM	Please clarify manufacturer and product to be used as basis of bid, no details provided. Reference: Exhibit H Question: Exhibit H includes several forms which have spaces that designate 'contractor'subcontractor'. Please clarify		Addendum #6 - 10/15/2024
Ohno Construction Company	10/03/2024 3:09:46 PM		Exhibit H forms from subcontractors are not required to be submitted at time of bid, however they will need to be provided before a notice to proceed is issued.	Addendum #3 - 10/7/2024
Ohno Construction Company	10/03/2024 3:52:07 PM	Would the TPL consider postponing the due date for this bid by (preferably) one week, to allow more time for additional subcontractors to respond with quotes?	The bid due date will be postponed to Tuesday, October 22, at 1pm Pacific.	Addendum #6 - 10/15/2024
AMG & Associates, Inc.	10/03/2024 4:53:34 PM	Regarding the HUB 3 requirement, is there a specific percentage that the GC is required to fulfill?	The Project should meet 25% Section 3 labor hours overall and 5% targeted Section 3 labor hours. The 5% targeted is a part of the 25% overall, and both can include subcontractor hours as part of meeting the	Addendum #3 - 10/7/2024
		,	include subcontractor hours as part of meeting the benchmarks.	
AMG & Associates, Inc.	10/03/2024 4:53:34 PM	Sheet L-1.01 has a Fitness Equipment Legend. I can't find this equipment on the plans. Is this required? If so please provide specification, location and details.	Yes, this is required. The equipment is located at the upper left edge of the playgroudn identified by callouts "A", "B", and "C", thoe ther equipment is to the right of the center patio andsplash pad identified by callouts "D", "E", "F" and "G". Under the "Site Amenities" portion of the construction legend, line item "SA-11" you can find the manufacturer contact info colors and	Addendum #4 - 10/10/2024
AMG & Associates, Inc.	10/03/2024 4:59:13 PM		you can find the manufacturer, contact info, colors and finishes. The exercise equipment legend has the model numbers.	
AMG & Associates, Inc. AMG & Associates, Inc.	10/03/2024 4:59:13 PM 10/03/2024 4:59:38 PM	Please provide specs for video surveillance Please provide specs, model numbers, manufacturers etc for site furnishings	See sheet E-5.00 titled Security Camera Cut Sheets. Please refer to sheet L-1.00 Construction Schedule and Notes. Product model numbers, manufacturers and their contact info, colors and finishes are listed under the "Site Amenitites Legend" portion.	
	10/03/2024 8:53:55 AM	Reference: Exhibit G – Forms to Submit with Bid Question: This section states that a City license needs to be submitted with the bid. Can the City of El Monte license be provided post bid, prior to Notice of Award, by the apparent low bidder	Contractor will be required to provide a copy of or apply for a City of El Monte Business License. This can	Addendum #4 - 10/10/2024
Ohno Construction Company	I		I	
Ohno Construction Company Ohno Construction Company	10/03/2024 8:54:26 AM	Reference: Request for Bid, Section 2C Question: This section, #3, requests that a CPM schedule be submitted with the bid. Since the NTP date is not firm, this schedule will not be accurate. We would like to request that submission of the schedule be made prior to NOIA, or	·	Addendum #3 - 10/7/2024