

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump EMAIL: rj.stump@fillmoreusd.org Fillmore Unified School Dist. Roy Frey WestGroup Designs royf@westgroupdesigns.com	
DATE:	January 23, 2025		
FROM:	Icon West, Inc. 520 S. La Fayette Park Pl, Suite 503 Los Angeles, CA 90057	EMAIL:	felix@icon-west.com
DOCUMENT/DIVISION NUMBER:		DRAWING NUMBER:	Plans A2-3.1, A5-1.1- Stainless Cove base

REQUESTED CLARIFICATION: #03

Please confirm these Rooms:105,106,112,117,113,121, will have B2 - Stainless Steel Cove base per A2-3.1 and A5-1.1, not a Tile Base.

PRE-BID CLARIFICATION FORM

RESPONSE TO CLARIFICATION:

Correct, the stainless steel cove base - Schluter will be used as a base;
not tile.

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.