

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump EMAIL: rj.stump@fillmoreusd.org Fillmore Unified School Dist. Roy Frey WestGroup Designs royf@westgroupdesigns.com	
DATE:	January 23, 2025		
FROM:	Icon West, Inc. 520 S. La Fayette Park Pl, Suite 503 Los Angeles, CA 90057	EMAIL:	felix@icon-west.com
DOCUMENT/DIVISION NUMBER:		DRAWING NUMBER:	A2-1.1 , A5-1.8 - Caseworks

REQUESTED CLARIFICATION: #04

Floor plan A2-1.1 shows an indication of Caseworks at Sports Offices rooms 109, 131, 122, 123, 115, 116, but in sheet A5-1.8, only shows an elevation of Room 131 Coach Office (typ). Is this Casework Elevation similar and applicable in all the other Sports Rooms, listed above. Please

PRE-BID CLARIFICATION FORM

RESPONSE TO CLARIFICATION:

Correct. The casework in the sports offices are all the same layout. The only adjustment will be the sizing for the center cabinets which should be equal between the 4 doors.

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.