

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump EMAIL: rj.stump@fillmoreusd.org Fillmore Unified School Dist. Roy Frey WestGroup Designs royf@westgroupdesigns.com	
DATE:	1/22/25		
FROM:	Bowe Contractors Inc.	EMAIL:	msoffa@bowecontractors.com nhulin@bowecontractors.com
DOCUMENT/DIVISION NUMBER:	04 20 00 Unit Masonry	DRAWING NUMBER:	detail 20 sheet S2-1.1

REQUESTED CLARIFICATION: #1

At the 40"x40" CMU pilasters and larger pilasters, please confirm that the intention is to grout solid the center void of these pilasters .

PRE-BID CLARIFICATION FORM

RESPONSE TO CLARIFICATION:

Correct.

Travis Culp - RTM (1/23/25)
Received 01/23/25

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.