

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump EMAIL: rj.stump@fillmoreusd.org Fillmore Unified School Dist. Roy Frey WestGroup Designs royf@westgroupdesigns.com	
DATE:	January 23, 2025		
FROM:	Icon West, Inc. 520 S. La Fayette Park Pl, Suite 503 Los Angeles, CA 90057	EMAIL:	felix@icon-west.com
DOCUMENT/DIVISION NUMBER:	Applied Fire Proofing (No Specs)	DRAWING NUMBER:	G-6.3, G-6.4, G-6.5

REQUESTED CLARIFICATION: #01

In several details, there are call outs for applied fire proofing to beams per details : 4.23/G-6.3, 4.33/G-6.4, 5.40/G-6.5, but there is no Specs for it. Please clarify if Fireproofing is required, if so, please provide specs and provide information where to apply.

DSA IR25-2 Details are specific to the acoustic ceiling system and the fire proofing shown on the mentioned details is not required.

Roy Frey - Westgroup Designs - 01/24/2025