

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump Fillmore Unified School Dist.	EMAIL: rj.stump@fillmoreusd.org
		Roy Frey WestGroup Designs	royf@westgroupdesigns.com
DATE:	January 23, 2025		
FROM:	Icon West, Inc. 520 S. La Fayette Park Pl, Suite 503 Los Angeles, CA 90057	EMAIL:	felix@icon-west.com
DOCUMENT/DIVISION NUMBER:		DRAWING NUMBER:	22/S0-03, D/L3.3

Please clarify what is the width of the footing for the ramp retaining wall per detail 22/S0-03

Response:
Provide 4'-0" wide footing at detail 22/S0-03.

Travis Culp - RTM (1/27/25)
Received 01/27/25

SRW-002 SCALE: NO SC

CONCRETE STAIR ON GRADE	16
-------------------------	----

S.O.G. CONST. JOINTS AT COL.	11
------------------------------	----

1	TYP. VERT. PIPES OR COND. THRU FTG.	6
---	-------------------------------------	---

5	FOOTING POURED AGAINST EARTH	1
---	------------------------------	---

CONCRETE BASE FOR EQUIPMENT	17
-----------------------------	----

DEPRESSED S.O.G. AND SLAB EDGE	12
--------------------------------	----

2	CONTINUOUS FOOTING CONST. JOINT	7
---	---------------------------------	---

7	PIPES PARALLEL TO FOOTINGS	2
---	----------------------------	---

--	--

TOP & BOTT.

CONCRETE CURB AND PADS	13
------------------------	----

3 PIPES AND CONDUIT PERPENDICULAR TO FOOTING

TINGS	3
-------	---

--	--

SITE RETAINING WALL	19
---------------------	----

REINF. AT FTG. OR WALL INTERSECTION	14
-------------------------------------	----

4	METHOD OF POURING S.O.G.	9
---	--------------------------	---

0	STEPPED FTG. TWO LAYERS OF REINF.	4
---	-----------------------------------	---

	20
--	----

PAD FOOTING SCHEDULE	15
----------------------	----

5	JOINT IN SLAB ON GRADE	10
---	------------------------	----

0	STEPPED FTG: ONE LAYER OF REINF.	5
---	----------------------------------	---

19900 MacArthur Boulevard | Suite 1000
Irvine | California | 92612
949.250.0880 | FAX 949.250.0882
www.westgroupdesigns.com

1 Ada, Suite 100 | Irvine, CA 92618
Tel (949) 462-3200 • Fax (949) 462-3201
WWW.RTMEC.COM

RTM Job No.: 23.WGD001.1113(352.020)

ISSUED FOR:

REVISIONS:

01 - PREBID ADDENDUM 01

REGISTRATION/SIGNATURE: _____

SHEET TITLE:

TYPICAL CONCRETE DETAILS

SHEET NUMBER:

S0-03

WD PROJ. #	DRAWN BY:	CHECKED	DATE
22851	Author	Checker	11/14/2024

© WESTGROUP DESIGNS, INC.