

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump EMAIL: rj.stump@fillmoreusd.org Fillmore Unified School Dist. Roy Frey WestGroup Designs royf@westgroupdesigns.com	
DATE:	January 23, 2025		
FROM:	Icon West, Inc. 520 S. La Fayette Park Pl, Suite 503 Los Angeles, CA 90057	EMAIL:	felix@icon-west.com
DOCUMENT/DIVISION NUMBER:		DRAWING NUMBER:	Alt #1 Boy's Locker Room A1-3.1, A1-3.2

REQUESTED CLARIFICATION: #06

The handrails at the new ramp shown on sheet A1-3.1 do not call out a finish and the handrails for the new stairs shown on sheet A1-3.2 do not show a finish. Will these handrails be galvanized or painted?

PRE-BID CLARIFICATION FORM

RESPONSE TO CLARIFICATION:

Confirmed - Handrails to have galvanized finish - see spec section 05 52 13 for additional information.

Roy Frey - Westgroup Designs - 01/24/2025

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.