

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump EMAIL: rj.stump@fillmoreusd.org Fillmore Unified School Dist. Roy Frey WestGroup Designs royf@westgroupdesigns.com	
DATE:	01/23/25		
FROM:	AMG & Associates, Inc David Silva 661-251-7401	EMAIL:	estimating@amgassociatesinc.com
DOCUMENT/DIVISION NUMBER:		DRAWING NUMBER:	

REQUESTED CLARIFICATION:

Per the Structural Drawings and Specifications, there is no callout or detail for CMU Control Joints. Is this correct? If CMU Control Joints are required please advise and provide maximum Spacing Requirements.

Response:

Correct.

Travis Culp - RTM (1/24/25)

Received 01/24/25