

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		<b>RJ Stump</b> EMAIL: <a href="mailto:rj.stump@fillmoreusd.org">rj.stump@fillmoreusd.org</a> Fillmore Unified School Dist.  <b>Roy Frey</b> WestGroup Designs <a href="mailto:royf@westgroupdesigns.com">royf@westgroupdesigns.com</a>	
DATE:	01/30/25		
FROM:	AMG & Associates Inc David Silva 661-251-7401	EMAIL:	<a href="mailto:estimating@amgassociatesinc.com">estimating@amgassociatesinc.com</a>
DOCUMENT/DIVISION NUMBER:	23 09 00	DRAWING NUMBER:	M0-4.1

REQUESTED CLARIFICATION:
<p><b>Please circle all applicable bid packages below, that this RFI pertains to:</b></p> <p><b>Base bid</b></p> <p><b>Alt #1</b></p> <p><b>Alt #2</b></p> <p>In the Mechanical specifications for the Athletic Complex is stating that the HVAC DDC Controls shall be Carrier OPEN BACnet by Russell Sigler.</p> <p>The Mechanical specifications for the Locker Room state that the controls shall be Johnson Controls (District Standard).</p> <p>Please clarify what HVAC controls system is to be used.</p> <p>Response By: PEI 01-31-2025          For Base Bid (Athletic Complex) and for Alternate #1 (Locker Room) utilize Carrier OPEN BACnet DDC Controls by Russell Sigler.          For Alternate #2 (Library) utilize programmable thermostats per contract document requirements.</p>