

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump EMAIL: rj.stump@fillmoreusd.org Fillmore Unified School Dist. Roy Frey WestGroup Designs royf@westgroupdesigns.com	
DATE:	02/04/25		
FROM:	AMG & Associates Inc David Silva 661-251-7401	EMAIL:	estimating@amgassociatesinc.com
DOCUMENT/DIVISION NUMBER:	333113	DRAWING NUMBER:	C5.1

REQUESTED CLARIFICATION:
<p>Please circle all applicable bid packages below, that this RFI pertains to:</p> <p>Base bid</p> <p>Alt #1</p> <p>Alt #2</p> <p>On Sheet C5.1 shows 4 Manholes in the Profile View and & 7 Manholes on the Street View. Which is correct? Also, 3 of the Manholes have no Elevations. Please advise?</p>

PRE-BID CLARIFICATION FORM

RESPONSE TO CLARIFICATION:

There are total of 7 new sewer manholes.
Use 10' height from manhole rim to top of new sewer line. 02.10.2025

Coast Engineering Designs Inc.
Farhad Rezai
Civil Engineer

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.