

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump Fillmore Unified School Dist. EMAIL: rj.stump@fillmoreusd.org Roy Frey WestGroup Designs EMAIL: royf@westgroupdesigns.com	
DATE:	1/29/2025		
FROM:	Neil Hulin	EMAIL:	Nhulin@Bowecontractors.com
DOCUMENT/DIVISION NUMBER:	23 09 00	DRAWING NUMBER:	

REQUESTED CLARIFICATION:
<p>Please circle all applicable bid packages below, that this RFI pertains to:</p> <p>Base bid</p> <p>Alt #1</p> <p>Alt #2</p> <p>Base Bid (Athletic Complex) Mechanical Specification Section 23 09 00-2 calls for the HVAC DDC Controls to be Carrier OPEN BACnet installed by Russell Sigler.</p> <p>Alternate #1 (Locker Room) Mechanical Specification Section 23 09 00-2 calls for the HVAC DDC Controls to be Johnson Controls (District Standard).</p> <p>Please confirm that two different HVAC controls will be used on the same campus and the Carrier controls system will communicate with the Johnson Controls system.</p> <p>Response By: PEI 01-29-2025 For Base Bid (Athletic Complex) and for Alternate #1 (Locker Room) utilize Carrier OPEN BACnet DDC Controls by Russell Sigler. For Alternate #2 (Library) utilize programmable thermostats per contract document requirements.</p>