

# PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump Fillmore Unified School Dist.  Roy Frey WestGroup Designs	
		EMAIL: <a href="mailto:rj.stump@fillmoreusd.org">rj.stump@fillmoreusd.org</a>  <a href="mailto:royf@westgroupdesigns.com">royf@westgroupdesigns.com</a>	
DATE:	01/30/25		
FROM:	AMG & Associates Inc David Silva 661-251-7401	EMAIL:	<a href="mailto:estimating@amgassociatesinc.com">estimating@amgassociatesinc.com</a>
DOCUMENT/DIVISION NUMBER:	096500	DRAWING NUMBER:	A2-3.1

## REQUESTED CLARIFICATION:


Please circle all applicable bid packages below, that this RFI pertains to:

**Base bid**

Alt #1

Alt #2

What is the floor finish between the boys lockers (124)?



PRE-BID CLARIFICATION FORM

RESPONSE TO CLARIFICATION:

Floor finish between the boy's lockers is LVT1.

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.