

# PRE-BID CLARIFICATION FORM

PROJECT NAME:	FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX		
PROJECT NUMBER:	Project No. 2024-017 / DSA #03-123950		
TO:	RJ Stump Fillmore Unified School Dist.  Roy Frey WestGroup Designs		
	EMAIL: <a href="mailto:ri.stump@fillmoreusd.org">ri.stump@fillmoreusd.org</a> ,  EMAIL: <a href="mailto:royf@westgroupdesigns.com">royf@westgroupdesigns.com</a>		
DATE:	1/29/2025		
FROM:	Raymond Ramos	EMAIL:	<a href="mailto:ramosr@scanderson.com">ramosr@scanderson.com</a>
DOCUMENT/DIVISION NUMBER:	Direct Digital Control System for HVAC 23 09 00 - 2	DRAWING NUMBER:	Part 2 - Products 2.01 A & B

REQUESTED CLARIFICATION:
<p><b>Please circle all applicable bid packages below, that this RFI pertains to:</b></p> <p><b>Base bid</b>          Mechanical specifications for the Athletic Complex states the HVAC DDC Controls are to be Carrier OPEN BACnet by Russell Sigler. However, mechanical specifications for the locker room state the "district standard" controls are Johnson Controls.          Please confirm the use of Carrier OPEN BACnet DDC controls is correct and if so, it will be compatible with the existing Johnson Controls system.</p> <p><b>Alt #1</b>    N/A  <b>Alt #2</b>    N/A</p> <p>Response By: PEI 01-31-2025          For Base Bid (Athletic Complex) and for Alternate #1 (Locker Room) utilize Carrier OPEN BACnet DDC Controls by Russell Sigler.          For Alternate #2 (Library) utilize programmable thermostats per contract document requirements.</p>