

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump EMAIL: rj.stump@fillmoreusd.org Fillmore Unified School Dist. Roy Frey WestGroup Designs royf@westgroupdesigns.com	
DATE:	February 3, 2025		
FROM:	Icon West, Inc. 520 S. La Fayette Park Pl, Suite 503 Los Angeles, CA 90057	EMAIL:	felix@icon-west.com
DOCUMENT/DIVISION NUMBER:		DRAWING NUMBER:	Alt #2 - A2-2.11, 8/SD1

REQUESTED CLARIFICATION: #28

Sheet A2-2.11 indicates that the exterior wall receives infill SN 02. Detail 8/SD1 shows typical wall infill framing but does not provide wall size and whether or not the exterior infill receives plywood. Also there are no structural sheets reflecting this area. Please provide wall size and if infill will receive plywood.

Assume wall infill to receive exterior rated plywood. Verify in field.

Roy Frey - Westgroup Designs - 01/29/2025