

PRE-BID CLARIFICATION FORM

PROJECT NAME:	FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX		
PROJECT NUMBER:	Project No. 2024-017 / DSA #03-123950		
TO:	RJ Stump Fillmore Unified School Dist. Roy Frey WestGroup Designs		
	EMAIL: ri.stump@fillmoreusd.org , EMAIL: royfawest2roupdesigns.com		
DATE:	5-Feb		
FROM:	SC Anderson - Raymond Ramos	EMAIL:	ramosr@scanderson.com
DOCUMENT/DIVISION NUMBER:	Spec Section 03 35 11 Polished Concrete Finishing	DRAWING NUMBER:	A2-3.1

REQUESTED CLARIFICATION:

Please circle all applicable bid packages below, that this RFI pertains to:

Base bid

Alt #1

Mt #2

Specification Section 03 35 11 Polished Concrete Finish is provided however polished concrete is not shown on the Finish Plan A2-3.1. Is polished concrete used on this project? If so, please clarify where.

RESPONSE:

THERE IS NO POLISHED CONCRETE IN THIS PROJECT. ONLY A CLEAR SEAL (CO1), PLEASE DISREGARD SPEC SECTION 03 35 11.

PRE-BID CLARIFICATION FORM

RESPONSE TO CLARIFICATION:

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.