

PRE-BID CLARIFICATION FORM

PROJECT NAME:		FILLMORE HIGH SCHOOL NEW ATHLETIC COMPLEX	
PROJECT NUMBER:		Project No. 2024-017 / DSA #03-123950	
TO:		RJ Stump Fillmore Unified School Dist. Roy Frey WestGroup Designs	
		EMAIL: ri.stump@fillmoreusd.org rovf@westgroupdesigns.com	
DATE:	2/5/2025		
FROM:	Neil Hulin	EMAIL:	nhulin@bowecontractors.com
DOCUMENT/DIVISION NUMBER:		DRAWING NUMBER:	E101

REQUESTED CLARIFICATION:

Please circle all applicable bid packages below, that this RFI pertains to:

Base bid

Alt #1

Alt #2

Locker room drawing sheet E101 shows existing IDF rack to be removed and rotated. Confirm to replace rotated with relocated. Please provide more information on this scope because there will not be enough spare cable to relocate the rack.

PRE-BID CLARIFICATION FORM

RESPONSE TO CLARIFICATION:

Existing IDF location to be relocated to other side of room. existing fiber to be pulled out and replaced with 12 strand single mode fiber reach relocated IDF Rack, allow service loops.
DL - AGD - 2/10/25

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.