

DATE:  
MAI NO.:  
DSA APPL. NO.:  
DSA FILE NO.:  
PTN:

July 11, 2025  
24001  
02-122658  
10-28  
62125-41

ADDENDUM FOR:

# **NEW CLASSROOM WING AT SUNSET ELEMENTARY SCHOOL**

COALINGA-HURON UNIFIED SCHOOL DISTRICT  
COALINGA, FRESNO COUNTY, CALIFORNIA

ADDENDUM  
NUMBER

6

NON-DSA

**ADDENDUM NO. 6**

**TO PROSPECTIVE BIDDERS:**

This Addendum forms a part of the Contract Documents and modifies the Contract Documents dated July 31, 2024.

**Bidders shall acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.**

This Addendum consists of printed pages and the following Attachments: None

**CHANGES TO PREVIOUSLY ISSUED ADDENDA**

**ITEM NO. 6.1:** Refer to Demo plans and Addendum No. 3:

- .1** ***Existing Electrical Enclosure:** Demolition of existing electrical enclosure and associated electrical equipment will need to remain in place until PG&E has provided new service to new utility yard identified in Addendum 3. Please allow 3.5 months for PG&E design and construction.*
- .2** *Bidders are to provide a \$180,000 allowance to accommodate any unforeseen impacts from the new PG&E service.*

**END OF ADDENDUM NUMBER 6**