


LEGEND


- FIRE LANE LOCATION
- PROPOSED HYDRANT
- EXISTING HYDRANT
- FIRE LANE NO PARKING SIGN LOCATIONS
- HOSE LAY DISTANCE FROM FIRE ENGINE TO A HYDRANT.
(225' MAX. WITH THRU ROAD)
(175' MAX. WITH DEAD-END)
- HOSE PULL DISTANCE FROM FIRE ENGINE TO MOST REMOTE
POINT OF PERIMETER OF STRUCTURE.
(150' MAX.)
- PROPERTY LINE

CANOPY AT GREAT PARK
PHASE 2
SEC OF BEACON AND HORNET
CITY OF IRVINE, CA

10870 W. FAIRVIEW DR
STE 102-1187
BOISE, ID 83713
(208) 918-0928
thomas@c3civileng.com
www.c3civileng.com



PROFESSIONAL SEAL



DATE: 04/22/2026
CS JOB NO: 24-036
DRAWN BY: TH
CHECKED BY: TH

SHEET TITLE

FIRE MASTER PLAN

SHEET NUMBER
3 of 3