

**WEST END REGIONAL NAVIGATION CENTER PROJECT**  
**BID NO.: DE-26-222-SB**

Addendum No. 4 Information  
June 25, 2026

To All Prospective Bidders, the following changes have been made to the bid.

1. **Q&A**

- 1.1 **Revised** released answer to question “3.15” shall replace previously released “3.15” response.
  - a. Clarify response to posed question.
- 1.2 **Revised** released answer to question “3.16” shall replace previously released “3.16” response.
  - a. Clarify response to posed question.
- 1.3 **Revised** released answer to question “3.17” shall replace previously released “3.17” response.
  - a. Clarify response to posed question.
- 1.4 **Revised** released answer to question “3.18” shall replace previously released “3.18” response.
  - a. Clarify response to posed question.
- 1.5 **Revised** released answer to question “3.19” shall replace previously released “3.19” response.
  - a. Clarify response to posed question.
- 1.6 **Revised** released answer to question “3.20” shall replace previously released “3.20” response.
  - a. Clarify response to posed question.

See attached.

## Addendum No. 4 – 1

**1.1.a Question:** Please confirm existing Firewater pressure has been tested for new sprinkler capacity.

**Answer:** To our knowledge, there has not been a firewater test performed for the building.

**1.2.a Question:** Please advise if exterior of building should be repainted or if only locations to receive new openings is applicable.

**Answer:** Where infill occurs, repaint building.

**1.3.a Question:** Is there a required fire alarm system manufacturer for this building?

**Answer:** Preferred manufacture for the fire alarm system is "Notifier" or approved equal.

**1.4.a Question:** Drawing SP-1.1 indicates a bike room; however, no information is provided regarding bike racks. Please confirm the following: Please confirm bike racks are to be within GC scope of work If included, provide required quantity/capacity (number of bikes). Provide specifications or basis-of-design for the bike rack system.

**Answer:** Bike racks are new and should be provided by GC: (2) 9 bike capacity (WB652771) and (1) 5-bike capacity by Global Industrial; powder coated steel. Provide anchoring at appropriate substrate.

**1.5.a Question:** Addendum #2 revised wall tiles WT-8, and WT-10 (ref. sheet A-4.1). The revised colors (#0076 Green Apple and #0058 Restore) are unavailable in the 8"x24" size. Please provide new color selections, noting that all Vibrant+ colors within the Color Storyline are unavailable in the 8"x24" size.

**Answer:** Use 4" x 12" tile to keep the same pattern and colors to make the pattern resemble an 8" x 24" pattern.

**1.6.a Question:** The 1st Floor Finish Plan (A-4.1) indicates FT-3 at shower pan locations for Rooms 114, 135, 137, 138, 162, 179, 180, and 182; however, FT-3 is not listed in the Finish Legend. Please provide information for FT-3.

**Answer:** FT-3 has been added to the Finish Legend. It is the same spec as FT-2 but in a 1" x 24" mosaic tile.