

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than **July 16, 2026, 5:00 p.m.**)

RECEIVED

By Juvoni Sterling at 8:46 am, Jul 06, 2026

To: **Juvoni Sterling, Project Director**
Department of Forestry and Fire Protection
Technical Services Section (TSS)
Phone: 916-709-0777

Email: Juvoni.Sterling@fire.ca.gov

TSS RFBI No.: **14**
Requestor RFBI No.: 10
Request Date: 7/2/26
From (Bidder): Gustav Keoni dba
Precision Construction
Services
Contact: Ruby Cruz
Phone: (805)458-0756
Fax: N/A
Email: precon@precision.services

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 3540SRAEUCO0182
Project Name: Parkfield Fire Station Facility Replacement
Location: 70331 Vineyard Canyon Road, Parkfield, California

Drawing Reference: ES101 - ELECTRICAL Project Manual Reference: NA
SITE PLAN

Question:

Please provide PG&E approved handout drawing.

See attached PG&E Construction Sketch which was incorporated into the project drawings.

G. Vincent

Bidder's Authorized Signature: Ruby Cruz

[] Check here if additional pages attached

Page 1 of 1

LEGEND

APPLICANT'S CONTACT
SPENCER THOMAS
CONTACT: 360-7773-7361

CONSTRUCTION NOTE:
-APPLICANT TO MAINTAIN 3'
HORIZONTAL & 1' VERTICAL
TRENCH SEPARATION FROM
ANY WET FACILITY.

REVISED SKETCH

Latitude: 35.90077 (35° 54' 03" N)
Longitude: -120.44519 (120° 26' 3" W)
Elevation: 1540.0 feet
City: No Data
District: PASO ROBLES
Division: Los Padres
County: Monterey
Corrosion Area: Non-Corrosion
Raptor Concentration Zone (RCZ)? : Yes
Area Designation: State Responsibility Area
Fire Management Area: No Designation
Peak Wind: 100-110 mph (3 sec-gust)
Summer Temperature District: Interior
Snow Loading Area: Intermediate
Climate Zone Code: X
Fire Index Area: 497
Fire Index Control Centers: No records
High Fire Threat District: Tier 2
Surge Protection Districts: District 2
Primary Voltage Area: 1
Insulation Areas: C

VICINITY SKETCH
NOT TO SCALE

CONSTRUCTION SKETCH
70331 VINEYARD CANYON RD, PARKFIELD
NEW BUSINESS – CAL FIRE STATION
INSTALL NON-RES. UG SVC TO 800A PANEL

PRIMARY VOLTAGE: 12	kV	VOLTAGE AREA: 1
LATITUDE: 35.902030		LONGITUDE: -120.446329
SOURCE SIDE DEVICE: 5595		
SUB & CIRCUIT: CHOLAME 2102		
DSGN SAG: 400	R.S.	RAPTOR ZONE: YES
LOADING AREA: INTERMEDIATE		ARRESTER DIST: 2
CORROSION AREA: NON		INSULATION DIST: C
EXEMPT EQUIP INST: YES		FIRE AREA: SRA-III

ENGINEERING AND PLANNING DEPT.
4325 S HIGUERA ST
SAN LUIS OBISPO, CA. 93401

EST: CHRIS CAMPBELL	530-513-9453
ADE: JAIME MARTINEZ	805-503-9607
SUPV: JOSHUA SCHWARTZ	661-599-1860
REP: DEIDRE CIMINO	408-206-8147
PLNR: ANDREW KARGOL	805-263-3438
NOTIF: 126868950	JPM: N/A
SCALE: 1"=30'	DATE: 4/8/2024
PN: 35495909	SHEET: 1 OF 1