

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than ~~June 30, 2020~~, 5:00 p.m.)

JULY 16, 2026

RECEIVED

By Juvoni Sterling at 11:35 am, Jul 10, 2026

To: Juvoni Sterling, Project Director
Department of Forestry and Fire Protection
Technical Services Section (TSS)
Phone: 916-709-0777

Email: Juvoni.Sterling@fire.ca.gov

TSS RFBI No.: 19

Requestor RFBI No.: 02

Request Date: 7/10/26

From (Bidder): _____

Electricraft Inc.

Contact: Christopher Stark

Phone: 805-801-3615

Fax: N/A

Email: cstark@electricraftinc.com

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 3540SRAEUCO0182

Project Name: Parkfield Fire Station Facility Replacement

Location: 70331 Vineyard Canyon Road, Parkfield, California

Drawing Reference: ES 101 Project Manual Reference: _____

Question: Sheet ES101, Keynote #6 asks to provide four (4) flagpole lights, but the drawing only shows three (3). What is the correct amount?

Response:

Drawings indicate four (4) Flagpoles lights located around the three flags. Four (4) flagpole light fixtures is the correct amount.

S. Thomas



Bidder's Authorized Signature: _____

[] Check here if additional pages attached

Page 1 of _____