

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than **July 16, 2026, 5:00 p.m.**)

RECEIVED

By Juvoni Sterling at 1:45 pm, Jul 10, 2026

TSS RFBI No.: 20

Requestor RFBI No.: 1

Request Date: 7/10/26

From (Bidder): Smith MEP

To: Juvoni Sterling, Project Director
Department of Forestry and Fire Protection
Technical Services Section (TSS)
Phone: 916-709-0777

Email: Juvoni.Sterling@fire.ca.gov

Contact: Brandon May

Phone: 805-956-8229

Fax: bmay@smithmep.com

Email: _____

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 3540SRAEUCO0182
Project Name: Parkfield Fire Station Facility Replacement
Location: 70331 Vineyard Canyon Road, Parkfield, California

Drawing Reference: ES101, E604 Project Manual Reference: _____

Question:

Under ground hand holes- There are multiple com and electrical pull boxes labeled with a description number on the electrical site plan ES101, and conduit schedule E604. Is there or will there be a pull box sheet showing sizes needed with respect to the pull box number?

Response:

There is no sheet showing box sizes.
Please see the schedule to the right.

S. Thomas

PULL BOX SCHEDULE

ID	SIZE (H X L)	ID	SIZE (H X L)
EPB1	30 X 48	UCPB1	30 X 48
EPB2	10 X 17	UCPB2	30 X 48
EPB3	24 X 36	UCPB3	30 X 48
EPB4	30 X 48	UCPB4	30 X 48
EPB5	10 X 17	UCPB5	30 X 48
EPB6	24 X 36	CPB1	10 X 17
EPB7	24 X 36	CPB2	10 X 17
EPB8	13 X 24	CPB3	10 X 17
EPB9	30 X 48	CPB4	10 X 17
EPB10	10 X 17	CPB5	24 X 36
EPB11	10 X 17	CPB6	10 X 17
EPB12	10 X 17		
EPB13	10 X 17		

Bidder's Authorized Signature: _____

[] Check here if additional pages attached

Page 1 of _____